



**MISSION SPRINGS WATER DISTRICT
STANDARD DRAWINGS**

SEPTEMBER 2012

TITLE	DWG #
Typical Line Types	D-01
Typical Legend	D-02
Curve Data Table, Manhole Legend, and Construction Notes Table	D-03
Typical Title Block	D-04
Typical Sewer Cover Sheet	D-05
Typical Sewer Plan and Profile Sheet	D-06
Typical Water Cover Sheet	D-07
Typical Water Plan and Profile Sheet	D-08
Fire Flow Certifications	D-09
Parallel Separations	G-01
Perpendicular Separations	G-02
Separation Notes	G-03
Post Meter Recycled Water Separations	G-04
Marker Post Installation	G-05
Guard Post Installation	G-06
Typical Sewer Trench	S-01
Sewer Bedding	S-02A
Concrete Sewer Bedding	S-02B
Manhole Frame and Cover	S-03
Manhole Collar and Grade Rings	S-04
4' Diameter Pre-cast Manhole	S-05
5' Diameter Pre-cast Manhole	S-06
Terminus Manhole With Laterals	S-07
Knuckle Manhole With Laterals	S-08
Shallow Manhole	S-09
Hot Tap Manhole	S-10
Inside Drop Manhole	S-11
Main Line Cleanout	S-12
Sewer Lateral	S-13
Deep Sewer Lateral	S-14
Deep Sewer Lateral with Utility Crossing	S-15
Hot Tap Sewer Lateral	S-16
Sewer Lateral on Private Property	S-17
Grease Interceptor	S-18

Water Trench Detail	W-01
Valve Installation	W-02
Triangular Water Valve Frame and Cover	W-02A
2" Diameter Blow-off Assembly	W-03
4" Diameter Blow-off Assembly	W-04
1" or 2" Air Valve Installations	W-05
1" or 2" Polyethylene Air Valve Enclosure	W-05A
4" or Larger Air Valve Assembly	W-06
6" Diameter Fire Hydrant Assembly	W-07
Fire Hydrant Location	W-07A
Horizontal Thrust Blocks	W-08
Vertical Thrust Blocks	W-08A
Thrust Block Bearing Area Table	W-08B
Restrained Joint Requirements	W-08C
1" and 2" Diameter Service Lateral Installation	W-09
Pipe Support Detail	W-10
Obstruction Under-crossing	W-11
4", 6", 8", or 10" Double Check Detector Assembly Above Grade Installations	W-12
4", 6", 8", or 10" Double Check Detector Assembly Underground Installations	W-13
¾", 1", 1 ½", or 2" Reduced Pressure Backflow Preventer	W-14
Bacteriological Sample Station Assembly	W-15
3" Water Meter Vault Installation	W-16
3" Water Meter Installation Notes and Material List	W-16A
4" or 6" Water Meter Vault Installation	W-17
4" or 6" Water Meter Installation Notes and Material List	W-17A
3" through 6" Reduced Pressure Backflow Preventer	W-18
Temporary Chlorination Point	W-19